

**NATIONAL INSTITUTE OF PUBLIC HEALTH -
NATIONAL INSTITUTE OF HYGIENE**

DEPARTMENT OF ENVIRONMENTAL HYGIENE

24 Chocimska 00-791 Warsaw ■ Phone (22) 5421354; (22) 5421349 ■ Fax (22) 5421287 ■ e-mail: sck-zhk@pzh.gov.pl

HK/B/1069/01/2015
ORIGINAL

HYGIENIC CERTIFICATE

Product: Chemical Resistant SPC by Durcon

containing hardened phenolic resin, cellulose fibre, and dyes

destined for application as laboratory worktops, fume cupboard tops and lining and sink units in public buildings, including health care buildings, industrial plants, and service centres.

is acceptable according to hygienic criteria with the following conditions:

If applied in health care buildings, the product needs to comply with the requirements of the regulation of Minister of Health of 26 June 2012 (Journal of Laws 2012.739 of 29 June 2012) on detailed requirements to be met by premises and equipment of entities involved in medical activities. If applied within premises with increased hygienic requirements, the product should be protected against impact and abrasion and cleaned with substances intended for clean premises and meet the requirements of ISO 5 class according to ISO 14644-1.

Hygienic certificate does not apply to technical parameters and utility value of the product

Producer POLYREY France
700 Route de Bergerac
24150 Benevil, France

This certificate was issued for
Durcon Company of Poland Sp. z o. o.
87-100 Toruń
ul. Ceglana 10

The certificate may be corrected or cancelled after appropriate motivation. The certificate loses its validity after 2020-10-15 or in the case of changes in composition or in technology of production.

Date of issue of the certificate: 15 October 2015

Head
Department of Environmental Hygiene
dr Bożena Krogulska
/-/ illegible signature

The Hygienic Certificate cannot be reproduced, copied, photographed, scanned, digitalized for marketing purposes without an approval of NIZP-PZH.

www.pzh.gov.pl